

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 11/12/2014
FORM APPROVED
OMB NO. 0938-0391

| | | | | | | | |
|---|--|--|--|--|--|--|----------------------------|
| STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION | | (X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 15G628 | | (X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____ | | (X3) DATE SURVEY COMPLETED 10/31/2014 | |
| NAME OF PROVIDER OR SUPPLIER ABILITIES SERVICES INC | | | | STREET ADDRESS, CITY, STATE, ZIP CODE 2 FREEMAN ST ROSSVILLE, IN 46065 | | | |
| (X4) ID PREFIX TAG | SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION) | | | ID PREFIX TAG | PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY) | | (X5) COMPLETION DATE |
| K 000 | <p>INITIAL COMMENTS</p> <p>A Life Safety Code Recertification Survey was conducted by the Indiana State Department of Health in accordance with 42 CFR 483.470(j).</p> <p>Survey Date: 10/31/14</p> <p>Facility Number: 001194 Provider Number: 15G628 AIM Number: 100245710</p> <p>Surveyor: Phillip Komsiski, Life Safety Code Specialist</p> <p>At this Life Safety Code survey, Abilities Services Inc. was found in compliance with Requirements for Participation in Medicaid, 42 CFR subpart 483.470(j), Life Safety from Fire, and the 2000 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 33, Existing Residential Board and Care Occupancies.</p> <p>This one story facility was sprinklered with a basement. The facility has a fire alarm system with smoke detection on all levels as well as in the corridors, common living areas and hard wired smoke detectors in all client sleeping rooms. The facility has a capacity of eight and had a census of eight at the time of this survey.</p> <p>Calculation of the Evacuation Difficulty Score (E-Score) using NFPA 101 A, Alternative Approaches to Life Safety, Chapter 6, rated the facility Prompt with an E-score of 0.48.</p> <p>Quality Review by Dennis Austill, Life Safety Code Specialist on 11/10/14.</p> | | | K 000 | | | |

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 11/12/2014
FORM APPROVED
OMB NO. 0938-0391

| | | | | | |
|---|--|--|--|----------------------------|--|
| STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION | | (X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 15G628 | (X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____ | | (X3) DATE SURVEY COMPLETED 10/31/2014 |
| NAME OF PROVIDER OR SUPPLIER ABILITIES SERVICES INC | | | STREET ADDRESS, CITY, STATE, ZIP CODE 2 FREEMAN ST ROSSVILLE, IN 46065 | | |
| (X4) ID PREFIX TAG | SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION) | ID PREFIX TAG | PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY) | (X5) COMPLETION DATE | |
| | | | | | |